



Linda S. Adams
Secretary for
Environmental Protection

California Regional Water Quality Control Board San Diego Region

Over 50 Years Serving San Diego, Orange, and Riverside Counties
Recipient of the 2004 Environmental Award for Outstanding Achievement from USEPA



Arnold Schwarzenegger
Governor

9174 Sky Park Court, Suite 100, San Diego, California 92123-4353
(858) 467-2952 • Fax (858) 571-6972
<http://www.waterboards.ca.gov/sandiego>

October 27, 2010

In reply refer to:
244506:adai

Mr. Steve Meyer, Deputy Director
Metropolitan Wastewater Division
City of San Diego
2392 Kincaid Road
San Diego, CA 92101-2309

Dear Mr. Meyer

**SUBJECT: REVIEW OF MONITORING REPORTS FOR NORTH CITY WATER
RECLAMATION PLANT**

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the August 2010 monthly monitoring report submitted by the City of San Diego in accordance with the Monitoring and Reporting Program of Order No. 97-03.

The following violation of the Order No. 97-03 was identified in the submitted monitoring reports:

1. The 12-month average effluent limitation for manganese of the discharge specification, established at 0.05 milligrams per liter (mg/L), was exceeded in August 2010 with reported values of 0.064 mg/L.

Please be aware this violation subjects you to possible further enforcement action by the San Diego Water Board, including administrative enforcement orders requiring the you to cease and desist from violations, or to clean up waste and abate existing or threatened conditions of pollution or nuisance; administrative assessment of civil liability in amounts of up to \$5,000 per day per violation;¹ and referral to the State Attorney General for injunctive relief.

The next monitoring report to be submitted is the September 2010 monthly and July-September 2010 quarterly monitoring report due by October 30, 2010.

¹ Under authority of California Water Code section 13350.

Mr. Meyer

- 2 -

October 27, 2010

For questions pertaining to the subject matter, please contact Amanda Dai at (858) 627-3977 or via email at adai@waterboards.ca.gov.

**PLEASE INCLUDE "244506:ADAI" IN THE SUBJECT LINE OF FUTURE
CORRESPONDANCE.**

Sincerely,

Robert Morris

Robert Morris, P.E.
Senior Water Resource Control Engineer
Cleanup and Land Discharge Branch

Regulatory Measure ID: 376374
Violation ID: 883610